



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 303-89-M Vol. 5

Manufacturer: RIF International Corporation
3875 Embassy Parkway
Fairlawn, Ohio 44333

Trade Name(s): Koroseal, Vicrtex, Sanitas, RJF, Korographics

Product: Light-weight vinyl-coated wallcovering
MEA Index #440-320 – Wall Covering

Pertinent Code Section(s): 27-348

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: Underwriters Laboratories, Inc. (UL) and
US Testing Co.

Test Report(s): UL File #4616 dated August 2, 1982
US Testing #062117-3A dated November 27, 1989.

Description: Light-weight vinyl-coated wallcovering having a maximum finished weight of 12.4 ounces per yard square. The wallcovering is manufactured by RJF International Corporation and is being marketed under the trade names of Koroseal, Sanitas, Vicrtex, RJF and Korographics.

Flame Spread Rating: 15
Smoke Developed Rating: 5

Terms and Conditions: The above-described wallcovering material, as having interior finish Class 'A' with flame spread and smoke developed ratings as indicated above, is accepted with the following conditions:

1. Upon exposure to fire, the material does not produce products of decomposition or combustion that are more toxic than those given off by wood when decomposing or burning under comparable conditions.
2. All shipments and deliveries of such material shall be provided with a certificate or label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance September 17, 2008

Examined By Siun Derkham